



VILLAGE OF LINCOLNWOOD

6900 Lincoln Ave. | Lincolnwood, IL 60712 | Phone: 847-673-7402

www.lincolnwoodil.org | commdev@lwd.org



Sewer Line, B-Box or Water Line Repairs Handout

A permit is required to install, replace or modify a lawn sprinkler system. All systems must comply with the [2014 Illinois State Plumbing Code](#), as amended.

An application must be submitted through our online portal at lincolnwood.onlana.com (you can also access the portal by scanning QR code above). You will need to apply an “Exterior Plumbing” permit and will need to include the following information:

The online permit application will require the following information:

- Homeowner Information including name, address, telephone number and email address
- Contractor Information: If contractors have not been selected at the time of application submitted, please note that a permit will not be issued until all contractors have been identified and registered with the Village.
- A detailed and enumerated proposal(s) from all contractors for all work with cost breakout, signed by the owner and contractors, scanned in pdf and uploaded – refer to [Illinois 815 ILCS 513/15 Section 15](#)
- Provide one (1) copy of the plat of survey (**not** a Google Earth image nor a site plan) showing the proposed location of the sewer repair, b-box and water line.

Please note the following:

Steel plates “trench plating” in the roadway are not allowed from November 1st through April 30th. Barricades will be required if the trench needs to be left open over night prior to cold patching.

Sewer line repairs and cleanout installations:

The following procedure will apply for all sewer repair inspections:

1. Pipe for sewer repair work shall be SDR 26 - 4" or 6", unless next to a water service the sewer pipe shall be SCH 40 PVC 4" or 6".
2. Pipe to be bedded in crushed stone (1/4"-3/4") CA 6 or grade 9.
3. The dewatering of an open excavation pit using a pump and hose shall terminate at a storm sewer inlet. The use of a street gutter to the storm inlet is not allowed.
4. The contractor shall call for an inspection approximately 1/2 hour prior to completion of the sewer repair, but no later than 2:30 PM.
5. When a sewer repair is completed after 2:30 PM, the inspection shall be scheduled for the following morning (Monday-Friday). Contractors are required to provide temporary protection for the area being repaired.
6. The Illinois Plumbing Code has been amended: Section 890.150(D) An approved trench box or shoring system shall be used to protect personnel where the depth of a trench is five (5) feet or more below grade.

B-Box and water line installations or repairs:

1. Water service lines shall comply with the [2014 Illinois State Plumbing Code](#).
2. Lead water service is not allowed and must be removed back to the main type K copper only per the Building Regulations chapter 14.4.3 section 890.1150(a)(1) Service lines greater than 2.5" shall be 2.5 inch diameter ductile iron.

Per Village of Lincolnwood ordinance for Site Management chapter 14.15.10(M) Permissible hours of construction:

Monday through Friday: 7:00 am to 6:00 pm


Saturday: 7:00 am to Noon

Sunday: Construction prohibited

For all direct burial installations or repairs, call J.U.L.I.E at either 811 or 1-800-892-0123 forty-eight (48) hours before you dig per Illinois State law. This is to verify the location of underground utilities in the area. The service is provided to you at no charge.

SKETCH IN LOCATION OF PROPOSED SEWER REPAIR WORK

INTERIOR LOT EXAMPLE



CORNER LOT EXAMPLE

