

Village of Lincolnwood
Second Addendum to the Request for Proposals
For Proesel Park Family Aquatic Center Water Slide Resurfacing
Dated: August 24, 2020

Answers to Questions

- 1) What coating is specified for the exterior surfaces of the slides? We use a polysiloxane on exterior surfaces.**
- a. The only specification as it related to surfacing is for the interior surfacing gel-coat. Specification were not made for any exterior surfaces.
- 2) When quoting the enclosed slide, do you want the entire interior surface resurfaced? Generally we do the start tub and exit piece along with the first section in and last section out. If you do want the entire interior surface of the enclosed slide resurfaced, do you want the whole 360 or just the bottom 180?**
- a. Due to the age of the slide we feel it may be best to resurface the slide in its entirety however a walk through can be made available upon request to see the slides on site to ascertain the need. Please indicate to what extent you will be resurfacing and what portions of the interior you are including in your proposal.