

- Section R602.4      Insert: "Interior load-bearing walls that contain plumbing piping, flues or ducts shall be constructed of a minimum of two-inch by six-inch lumber."
- Section R602.5      Insert: "Interior non-load-bearing walls that contain plumbing piping, flues or ducts shall be constructed of a minimum of two-inch by six-inch lumber."
- Section R703.1      Insert: "Application of other laws. The provisions of this article shall not be deemed to nullify any provisions of the Zoning Ordinance or any other ordinance, law or statute of the Village pertaining to the location or type of construction of buildings. All exterior walls shall be constructed in accordance with the applicable standards set forth in the Village of Lincolnwood Zoning Ordinance. The use of exterior insulation finishing systems ("EIFS") on exterior walls, such as Dryvit or similar products, is specifically prohibited."
- Section R703.9      Delete
- Section R703.9.1    Delete
- Section R703.9.2    Delete
- Section R806.3.1    Insert: "Insulation baffles. Where eave vents are provided, insulation baffles shall be installed between the rafters at the eaves to maintain air flow from the soffit vents."
- Chapters 11, and    Delete"  
25 - 43

SECTION 6. ADOPTION OF APPENDICES H AND J. Section 4 of Article 3 of Chapter 14 of the Village Code is hereby amended further to read as follows:

"14-3-4:      ADOPTION OF APPENDICES H AND J.

Appendix H, and Appendix J as set forth in the International Residential Code for One- and Two-Family Dwellings are hereby adopted by reference and are hereby made a part of this Article 3 with the same force and effect as if fully set forth herein."

SECTION 7. EXCEPTIONS, INSERTIONS AND ADDITIONS TO ILLINOIS PLUMBING CODE. Section 3 of Article 4 of Chapter 14 is hereby amended further to read as follows:

"14-4-3: EXCEPTIONS, INSERTIONS AND ADDITIONS.

The following items are the additions, insertions and changes to the Illinois Plumbing Code:

Illinois Plumbing Code Section	Change
Section 890.150(d) (new section)	Insert: "An approved trench box or shoring system shall be used to protect personnel where the depth of a trench is five feet or more below grade."
Section 890.320(I)(2)(A)	Insert: "Use of polyethylene (PE) prohibited."
Section 890.320(I)(2)(C)	Insert: "Use of polybutylene (PB) prohibited."
Section 890.1150(a)(1)	Insert: "Lead water service not allowed. Type K copper only."
Section 890.1150(a)(5) (new section)	Insert: "The domestic water service shall be separated from the fire service prior to entering the building or structure, and an approved shut-off valve shall be placed on the domestic water service prior to entering the building or structure."
Section 890.1210	Insert: "No plastic pipe, tubing or fittings allowed for potable water."
Section 890.1320(b)	Insert: "When a building addition includes the installation of additional plumbing fixtures, a televised test of the existing sewer service line must be conducted, with a tape copy of the test submitted to the Community Development Department to verify condition of the existing sewer service line. If it is determined that the existing sewer service line is not in serviceable condition, a new overhead type sewer service must be installed from the house to the Village sewer main. In the event that a new home is constructed or an existing home is increased in area by 50%, the existing sewer service line must be abandoned and a new overhead type sewer service line installed from the home to the Village sewer main."

Section 890.1500	Insert: "No wet venting allowed."
Section 890.1580(B)	Insert: "The diameter of an individual vent shall be not less than 1 1/2 inches."
Section 890, Appendix A, Table N	Insert: "The size of the water meter shall never be less than the size of the water supply pipe."

SECTION 8. ADOPTION OF INTERNATIONAL FIRE CODE. Section 2 of Article 5 of Chapter 14 of the Village Code is hereby amended further to read as follows:

"14-5-2: ADOPTION OF INTERNATIONAL FIRE CODE.

The International Code Council, Inc., 2009 edition of the International Fire Code is hereby adopted by reference as the fire code for the Village and is hereby made a part of this Article 5 with the same force and effect as if fully set forth herein, except, however, those exceptions, insertions and additions described in Section 14-5-3 of this Code."

SECTION 9. EXCEPTIONS, INSERTIONS AND ADDITIONS. Section 3 of Article 5 of Chapter 14 of the Village Code is hereby amended further to read as follows:

"14-5-3: EXCEPTIONS, INSERTIONS AND ADDITIONS.

The following items are the additions, insertions and changes to the International Fire Code:

International Fire Code Section	Change
Section 101.1	Insert: "Village of Lincolnwood"
Section 902.1	Delete: Definition of "Fire Area" in its entirety.
Section 902.1	Insert: "FIRE AREA: The aggregate floor area bounded by the exterior walls of a building or structure, regardless of fire walls, fire barriers or fire resistance-rated horizontal assemblies."
Section 903.2.1.1	Delete: "12,000"
Section 903.2.1.1	Insert: "5,000"
Section 903.2.1.3	Delete: "12,000"